



December 4, 2020

Mr. Bernie Bowers
Operations Supervisor
Wyandotte Public Schools
639 Oak Street
Wyandotte, Michigan 48192
bbowers@wy.k12.mi.us

RE: **AEG Project # AE180812**
Lead Drinking Water Sampling
Monroe Elementary School

Dear Mr. Bowers:

Pursuant to the request of Wyandotte Public Schools, Arch Environmental Group, Inc. (AEG) collected five (5) representative first draw drinking water lead samples on November 18, 2020, at Monroe Elementary School.

General Information about Lead

There is no federal law requiring testing of drinking water in schools and childcare facilities, except for those that have and/or operate their own public water system and therefore are subject to comply with the Safe Drinking Water Act (SDWA). Drinking water programs are conducted on a voluntary basis.

Lead enters drinking water:

1. *Through Corrosion*
Most lead gets into drinking water after the water leaves the local well or treatment plant and comes into contact with plumbing materials containing lead. These include lead pipe and lead solder (commonly used until 1986) as well as faucets, valves, and other components made of brass. The physical/chemical interaction that occurs between the water and plumbing is referred to as corrosion. The extent to which corrosion occurs contributes to the amount of lead that can be released into the drinking water.
2. *Faucet Aerators*
Many taps that are used to provide water for human consumption have an aerator as part of the faucet assembly. Screens are not intended to remove contaminants in the water but may trap sediment or debris as water passes through the faucet. Lead bearing sediment may end up in drinking water from physical corrosion of leaded solder and can build up in the aerator over time.
3. *Galvanized Piping*
Additionally, galvanized pipes are old iron pipes that were installed in many homes built before the 1960s. Over many years, old corrosion scales build up inside the walls of galvanized pipes. These pipes can cause discolored water and pressure issues. Galvanized pipes can also release lead in water if you have or ever have had a lead service pipe.


4. *Brass Pipes, Faucets Fittings and Valves*

Brass used prior to 2014 to deliver drinking water can contribute to lead levels at the tap. Lead has long been used in the foundry process to make brass castings pressure tight. Lead is sometimes added in concentrations of about 2%.

Action Levels

The Lead and Copper Rule (LCR) is a treatment technique rule. Instead of setting a maximum contaminant level (MCL) for lead or copper, the rule requires public water systems to take certain actions to minimize lead and copper in drinking water. The Action Level for lead is 15 ug/L (15 ppb). Beginning January 1, 2025, the action level for lead in the State of Michigan will be lowered to 12 ug/L (12 ppb). In August 2016, the Michigan Department of Environment, Great Lakes, and Energy (EGLE) recommended school districts use the contaminate level goal of 5 ug/L (5 ppb). Finally, in May of 2019, The American Academy of Pediatrics called for new federal standards to ensure water lead concentrations do not exceed 1 ug/L (1 ppb). For this sampling event, the District shall utilize 12 ug/L (ppb) as the Action Level.

Common Drinking Water Outlets



Collection Procedures

All water samples were collected utilizing 250 milliliters (mL) sample bottles as recommended in the August 1, 2016, Version 3.0 "EGLE Guidance on Drinking Water Sampling for Lead and Copper at Schools and Daycares on Community Water Supplies". Sample results are representative of the specific fixture sampled and do not represent the distribution system or other fixtures.

First Draw Sampling:

AEG collected first draw samples. A first draw is the water that is the first to come out of the tap after the period of 8-24 hours of inactivity.

All locations sampled identified lead below the 12 ug/L Action Level. No further action is recommended at this time.

If you have any questions regarding the report, please feel free to contact the cleanWATER team at (248) 426-0165 [office].

Sincerely,

Arch Environmental Group, Inc.
Environmental Services

Brendan Koziol

Brendan Koziol
Consultant

Attachments: Results Table
 Analytical Results & Chain of Custody



Wyandotte Public Schools
 Drinking Water Analysis
 Project Number: AE180812

Monroe Elementary School							
Date of Sampling: November 18, 2020							
Sampler: Evan Gist							
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Monroe-01	Room 9, Faucet	Faucet	10:42 AM	12	4	Yes	First Draw.
Monroe-02	Hallway, Outside of Library and Main Lobby, Hydration Station, Bottle Fill	Hydration Station	10:46 AM	12	ND ³	Yes	First Draw.
Monroe-03	Room 11, Faucet	Faucet	10:50 AM	12	3	Yes	First Draw.
Monroe-04	Room 14, Faucet	Faucet	10:56 AM	12	4	Yes	First Draw.
Monroe-05	Second Floor, Outside of Room 25, Hydration Station, Bottle fill	Hydration Station	10:58 AM	12	ND	Yes	First Draw.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee

2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>

3) ND = Non Detected at Reported Detection Limit of 1 ug/L

4) NT = Not Tested

December 02, 2020

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335

Subject: Monroe Elementary School IFD
AE180812-WPS

Dear Ms. Eveleth :

Thank you for making Brighton Analytical, L.L.C. your laboratory of choice. Attached are the results for the samples submitted on 11/19/2020 for the above mentioned project. NELAP/TNI Accredited Analysis and EGLE Drinking Water Certified Analysis will be identified in their respective reporting formats. Hard copies can be supplied at your request for a fee of \$20.00 per copy.

The invoice for this project will be emailed separately. If you have any questions concerning the data or invoice, please don't hesitate to contact our office. We welcome your comments and suggestions to improve our quality systems. Please reference Brighton Analytical, L.L.C. Project ID 71785 when calling or emailing. We thank you for this opportunity to partner with you on this project and hope to work with you again in the future.

Sincerely,
Brighton Analytical, L.L.C.



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
EGLE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 11/18/2020 10:42
Submit Date/Time: 11/19/2020 13:30
Report Date: 12/02/2020

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335


BA Project # **71785** Project Name: **Monroe Elementary School IFD**
BA Sample ID **CN07191** Project Number: **AE180812-WPS**
Sample ID: **Monroe-01 Room 9**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	4	ug/L	1.0	15	EPA 200.8 rev5.4	11:17	12/01/2020

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
Date 12/2/2020



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
EGLE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 11/18/2020 10:46
Submit Date/Time: 11/19/2020 13:30
Report Date: 12/02/2020

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335


BA Project # **71785** Project Name: **Monroe Elementary School IFD**
BA Sample ID **CN07192** Project Number: **AE180812-WPS**
Sample ID: **Monroe-02 HW Outside of Library & Main Lobby**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1.0	15	EPA 200.8 rev5.4	11:20	12/01/2020

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
Date 12/2/2020



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
EGLE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 11/18/2020 10:50
Submit Date/Time: 11/19/2020 13:30
Report Date: 12/02/2020

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335


BA Project # **71785** Project Name: **Monroe Elementary School IFD**
BA Sample ID **CN07193** Project Number: **AE180812-WPS**
Sample ID: **Monroe-03 Room 11**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	3	ug/L	1.0	15	EPA 200.8 rev5.4	11:29	12/01/2020

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
Date 12/2/2020



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
EGLE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 11/18/2020 10:56
Submit Date/Time: 11/19/2020 13:30
Report Date: 12/02/2020

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335


BA Project # **71785** Project Name: **Monroe Elementary School IFD**
BA Sample ID **CN07194** Project Number: **AE180812-WPS**
Sample ID: **Monroe-04 Room 14**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	4	ug/L	1.0	15	EPA 200.8 rev5.4	11:32	12/01/2020

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
Date 12/2/2020



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
EGLE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 11/18/2020 10:58
Submit Date/Time: 11/19/2020 13:30
Report Date: 12/02/2020

Arch Environmental Group
37720 Interchange Dr.
Farmington Hills, MI 48335


BA Project # **71785** Project Name: **Monroe Elementary School IFD**
BA Sample ID **CN07195** Project Number: **AE180812-WPS**
Sample ID: **Monroe-05 2nd Flr Single Bottle Fill O/S Rm25**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Lead (Drinking Water)	Not detected	ug/L	1.0	15	EPA 200.8 rev5.4	11:44	12/01/2020

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve EGLE designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by 
Date 12/2/2020



BRIGHTON ANALYTICAL, LLC

QUALITY ASSURANCE/QUALITY
CONTROL

ICP-MS

METHOD 200.8/6020

REPRESENTATIVE BATCH PRECISION AND ACCURACY QUALITY CONTROL SUMMARY

Analysis Date: 12/1/2020	Standard ID: 111120 H2O	Batch: 11/24/2020 B1
Matrix Spike Lab ID: CN07194	Matrix: Total	Analyst: MH

Metals	Matrix Spike - Precision *			Matrix Spike - Accuracy**				Miscellaneous***		
	Matrix Spike (ug/L)	Matrix Spike Dup (ug/L)	RPD (%)	Spk Conc (ug/L)	MS Recovery (%)	MSD Recovery (%)	Sample Conc (ug/L)	Method Blk (ug/L)	LCS-Method STD (%)	Ind. Std. (%)
Lead	979	1087	10.5	1000	97.5	108.3	4	<1	99.0	107.1

* Matrix spike precision range +/- 20% RPD

** Matrix spike accuracy range +/- 20% recovery

*** LCS accuracy range +/- 15% recovery / Ind std accuracy range +/- 10% recovery

Comments: _____